



Results Report

Order ID: 9045401

Miller & Sons Water Conditioning
2021 Horseshoe Road
Lancaster, PA 17602

Project: Health Science Campus
422 Beaver Valley Pike
Willow Street, PA 17584

Attn: Brandy Zaia

Regulatory ID:

Sample Number: 9045401-01	Site: 401	Sample ID: Downstairs Simulation Office Hand Si
Collector: KF	Collect Date: 04/25/2019 8:45 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/02/19	MAW	05/02/19 13:50	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 9045401-02	Site: 402	Sample ID: Kitchen Sink
Collector: KF	Collect Date: 04/25/2019 8:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/02/19	MAW	05/02/19 13:52	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 9045401-03	Site: 403	Sample ID: Men's Restroom
Collector: KF	Collect Date: 04/25/2019 8:55 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/02/19	MAW	05/02/19 13:54	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 9045401-04	Site: 404	Sample ID: Faculty Office #2
Collector: KF	Collect Date: 04/25/2019 9:00 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/02/19	MAW	05/02/19 14:00	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 9045401-05	Site: 405	Sample ID: Faculty Office #3
Collector: KF	Collect Date: 04/25/2019 9:05 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/02/19	MAW	05/02/19 14:01	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 05/02/2019 4:36 pm
STL_Results Revision #1.6

9045401
Effective: 07/09/2014





SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Kelly Mays
Project Manager II


Report Generated On: 05/02/2019 4:36 pm 9045401
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

610-



9045401
Kelly Mays

rd
3605
stinglabs.com

TAT (Circle One): Standard 24hr / 48hr / 72hr / Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Miller & Sons, Inc.
Address: _____ Phone: _____
Contact Name: Brandy Zava Fax: _____
Comments: _____ Email: _____

Project Name: Health Science Campus
Address: 422 Beaver Valley Pike
Willow Street, PA 17584
Payment / P.O. Info: _____

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
401	(Downstairs Simulation) office hand sink	4/24/19	0845	KF	Lead	1	PW	G	P		
402	(Kitchen sink)	4/24/19	0850	KF	Lead	1	PW	G	P		
403	(Men's restroom)	4/24/19	0855	KF	Lead	1	PW	G	P		
404	(Faculty office #2)	4/24/19	0900	KF	Lead	1	PW	G	P		
405	(Faculty office #3)	4/24/19	0905	KF	Lead	1	PW	G	P		

Relinquished By: <u>Lyle Zava</u>	Date: <u>4/24/19</u> Time: <u>1600</u>		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By: <u>[Signature]</u>	Date: <u>4-25-19</u> Time: <u>08:15</u>	Temp °C: <u>3.8</u> Acceptable: <u>Y/N</u>	Submitted with COC? <u>Y/N</u> Number of containers match number on COC? <u>Y/N</u> All containers in tact? <u>Y/N</u> Tests within holding times? <u>Y/N</u> 40 mL VOA vials free of headspace? <u>Y/N</u>	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	P = Plastic G = Glass O = Other	[] SDWA Reporting PWSID: _____ [] Fax [] Email [] Other _____ [] Return a copy of this form with Report
Relinquished By: <u>[Signature]</u>	Date: <u>4-25-19</u> Time: <u>12:20</u>	Temp °C: <u>3.2</u> Acceptable: <u>Y/N</u>		Sample Type Key	Preservative Key	
Received in Lab By: <u>MSM</u>	Date: <u>4-25-19</u> Time: <u>1220</u>	Temp °C: _____ Acceptable: <u>Y/N</u>		G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	