



**Excursion Notification Report**

**Attention: (Brandy Zaia)**

Dear Valued Client,

Thank you for choosing Suburban Testing Labs for your environmental testing needs . Below is your results notification, showing that we have entered a result that is above your specified action limit for one or more of your sampling locations.

For further information regarding these results, please contact  
Kelly Mays (kmays@suburbantestinglabs.com) 1-800-433-6595

Client: Miller & Sons Water Conditioning 2021 Horseshoe Road Lancaster, PA 17602	Project: CTC-Public Safety Training Center 101 Champ Boulevard Manheim, PA 17545
--	--

**Note:** Results have been validated (peer reviewed) but have not been approved

Sample Number: <b>9045628-01</b> Matrix: <b>Potable Water</b>	Sample Name: <b>401 (Men's Restroom across from Rm.100)</b>	Sampled on: <b>04/26/2019</b>
--	---	-------------------------------

Analyte	Result	Units	Flag Limit 1
Lead	0.167	mg/L	0.015

