



### Results Report

Order ID: 9045628

Miller & Sons Water Conditioning  
2021 Horseshoe Road  
Lancaster, PA 17602

Project: CTC-Public Safety Training Center  
101 Champ Boulevard  
Manheim, PA 17545

Attn: Brandy Zaia

Regulatory ID:

Sample Number: 9045628-01      Site: 401 (Men's Restroom across from Rm.1)      Sample ID:  
Collector: KF      Collect Date: 04/26/2019 9:10 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead      0.167      mg/L      EPA 200.8      0.001      1      05/06/19      MAW      05/06/19 11:10      RPV

Sample Number: 9045628-02      Site: 402 (Kitchen 2-Bay Sink)      Sample ID:  
Collector: KF      Collect Date: 04/26/2019 9:15 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead      < 0.001      mg/L      EPA 200.8      0.001      1      05/06/19      MAW      05/06/19 11:12      RPV

Sample Number: 9045628-03      Site: 403 (Men's Restroom -down hallway)      Sample ID:  
Collector: KF      Collect Date: 04/26/2019 9:20 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead      < 0.001      mg/L      EPA 200.8      0.001      1      05/06/19      MAW      05/06/19 11:14      RPV

Sample Number: 9045628-04      Site: 404 (Janitor's closet)      Sample ID:  
Collector: KF      Collect Date: 04/26/2019 9:25 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead      < 0.001      mg/L      EPA 200.8      0.001      1      05/06/19      MAW      05/06/19 11:16      RPV

Sample Number: 9045628-05      Site: 405 (Tool cage in 4 bay garage)      Sample ID:  
Collector: KF      Collect Date: 04/26/2019 9:30 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead      < 0.001      mg/L      EPA 200.8      0.001      1      05/06/19      MAW      05/06/19 11:18      RPV

**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 05/07/2019 4:04 pm      9045628  
STL\_Results Revision #1.6      Effective: 07/09/2014





# SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**


Kelly Mays  
Project Manager II

Report Generated On: 05/07/2019 4:04 pm 9045628  
STL\_Results Revision #1.6 Effective: 07/09/2014





**SUBURBAN TESTING LABS**



9045628  
Kelly Mays

TAT (Circle One): Standard 24hr / 48hr / 72hr / Other  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

Client Name: Miller & Sons, Inc.  
Address: \_\_\_\_\_ Phone: \_\_\_\_\_  
Contact Name: Brandy Zaira Email: \_\_\_\_\_

Client Name: CTC-Public Safety Training Center  
Address: 101 Champ Boulevard  
Manheim, PA 17545  
Payment / P.O. Info: \_\_\_\_\_

Comments:

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
401	(Men's restroom across from rm. 100)	4/26/19	0910	KF	Lead	1	PW	G	P		
402	(Kitchen 2-Bay sink)		0915		Lead	1	PW	G	P		
403	(Men's restroom - down hallway of main entrance)		0920		Lead	1	PW	G	P		
404	(Janitor's closet next to women's restroom)		0925		Lead	1	PW	G	P		
405	(Tool cage in 4 Bay garage)		0930		Lead	1	PW	G	P		

Relinquished By: <u>[Signature]</u>	Date: <u>4/26/19</u>	<u>Fridge</u>	Submitted with COC? <u>Y / N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
	Time: <u>1645</u>		Number of containers match number on COC? <u>Y / N</u>			
Received By: <u>[Signature]</u>	Date: <u>4/26/19</u>	Temp °C: <u>4.5</u>	All containers in tact? <u>Y / N</u>	Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence	Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO <sub>3</sub> C = HCl S = H <sub>2</sub> SO <sub>4</sub> OH = NaOH O = Other NA = None Required
	Time: <u>1725</u>		Acceptable: Y / N			
Relinquished By: <u>[Signature]</u>	Date: <u>4/26/19</u>	Temp °C: <u>6.5</u>	Tests within holding times <u>Y / N</u>	40 mL VOA vials free of headspace? <u>Y / N</u>		
	Time: <u>1815</u>		Acceptable: Y / N			
Received in Lab By: <u>[Signature]</u>	Date: <u>4-26-19</u>	Temp °C: _____				
	Time: <u>1815</u>		Acceptable: Y / N			

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.3 Effective May 16, 2013.

Shaded areas are for STL use only.