



Drinking Water Results Report

Order ID: 0082092

Miller & Sons Water Conditioning
2021 Horseshoe Road
Lancaster, PA 17602

Project: Health Science Campus
422 Beaver Valley Pike
Willow Street, PA 17584

Attn: Brandy Zaia

PWSID:

Sample Number: 0082092-01

Site: 702- Kitchen Sink

Sample ID:

Collector: KF

Collect Date: 08/04/2020 9:25 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	08/13/20	MKR	08/13/20 17:15	RJS
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

MCL: Maximum Contaminant Level based on 40CFR part 141 and 143. MCL and Pass/Fail are provided for reference only.

RL: Reporting Limit. The lowest concentration reported for this sample. Results below the RL are considered Non-Detected.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Ryan F Knerr
Project Manager II

Report Generated On: 08/14/2020 4:00 pm
STL_DW_Results Revision #1.7

0082092
Effective: 07/09/2014



SUBURBAN TESTING LABS

6

0082092
Lisa F. CareTAT (Circle One): Standard 24hr / 48hr / 72hr / Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Miller & Sons, Inc.

Address: _____ Phone: _____

Contact Name: Brandy Zaia Email: _____

Comments: _____

Name: Health Science Campus
Address: 422 Beaver Valley Pike
Willow Street, PA 17584
Payment / P.O. Info: _____

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	Kitchen sink (702)	8/4/20	0925	ICF	Lead	1	PW	G	P		
	(1) 250mLP ↳ preserved w/ 15 drops of HNO ₃ pH 2 LHA 8/5/20 12:48										

Relinquished By: <u>LFC 7</u>	Date: <u>8/4/20</u> Time: <u>1700</u>	Sample Conditions Submitted with COC? <u>(Y) / N</u> Number of containers match number on COC? <u>(Y) / N</u> All containers in tact? <u>(Y) / N</u> Tests within holding times <u>(Y) / N</u> 40 mL VOA vials free of headspace? <u>Y / N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options [] SDWA Reporting PWSID: _____ [] Fax [] Email [] Return a copy of this form with Report
Received By: <u>[Signature]</u> (1)	Date: <u>8-5-20</u> Time: <u>08:00</u> Temp °C: <u>39</u> Acceptable: <u>Y / N</u>				
Relinquished By: <u>[Signature]</u>	Date: <u>8-5-20</u> Time: <u>12:00</u> Temp °C: <u>39</u> Acceptable: <u>Y / N</u>				
Received in Lab By: <u>LHA (1)</u>	Date: <u>8/5/20</u> Time: <u>1230</u> Temp °C: <u>39</u> Acceptable: <u>Y / N</u>				

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.3 Effective May 16, 2013.
Shaded areas are for STL use only.



Results Report

Order ID: 0063028

Miller & Sons Water Conditioning
2021 Horseshoe Road
Lancaster, PA 17602

Project: Brownstown CTC Campus

Attn: Brandy Zaia

Regulatory ID: 7361063

Sample Number: 0063028-01

Site: 701 - Room 341

Sample ID:

Collector: KF

Collect Date: 06/09/2020 9:15 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 0.001 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 22:59 RPV

Sample Number: 0063028-02

Site: 702 Room 328

Sample ID:

Collector: KF

Collect Date: 06/09/2020 9:20 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 23:01 RPV

Sample Number: 0063028-03

Site: 703 - Room 317

Sample ID:

Collector: KF

Collect Date: 06/09/2020 9:25 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 23:03 RPV

Sample Number: 0063028-04

Site: 704 - Room 307

Sample ID:

Collector: KF

Collect Date: 06/09/2020 9:35 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 23:05 RPV

Sample Number: 0063028-05

Site: 705 - Room 306

Sample ID:

Collector: KF

Collect Date: 06/09/2020 9:40 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 0.002 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 23:07 RPV

Report Generated On: 06/22/2020 4:09 pm

0063028

STL_Results Revision #1.9

Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 0063028-06	Site: 706 - Romm 224	Sample ID:
Collector: KF	Collect Date: 06/09/2020 9:55 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 23:09	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0063028-07	Site: 707 - Room 205	Sample ID:
Collector: KF	Collect Date: 06/09/2020 10:00 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/19/20	RPV	06/19/20 21:39	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0063028-08	Site: 708 - Room 206	Sample ID:
Collector: KF	Collect Date: 06/09/2020 10:05 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/19/20	RPV	06/19/20 22:01	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0063028-09	Site: 709 - Room 124	Sample ID:
Collector: KF	Collect Date: 06/09/2020 10:15 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/19/20	RPV	06/19/20 22:03	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0063028-10	Site: 710 - Room 117	Sample ID:
Collector: KF	Collect Date: 06/09/2020 10:25 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/19/20	RPV	06/19/20 22:05	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 06/22/2020 4:09 pm
STL_Results Revision #1.9

0063028
Effective: 04/16/2020





SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Kelly Mays
Client Services Supervisor

Report Generated On: 06/22/2020 4:09 pm 0063028
STL_Results Revision #1.9 Effective: 04/16/2020





TAT (Circle One): Standard 24hr / 48hr / 72hr / Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Comments:

Project Name: Brownstown CTC Campus
Address: 231 Snyder Road
Ephrata, PA 17522
Payment / P.O. Info: _____


STL Sample Number		Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
								Matrix	Sample Type	Bottle Type	Preservative	
						presented with 20 drops of HNO ₃ . PHZZ TLB						
		701 Room 341	6/9/20	0915	ICF	lead 6/10/20 1450	1	PW	G	P		
		702 Room 328		0920		lead						
		703 Room 317		0925		lead						
		704 Room 307		0935		lead (8) 250 ml P						
		705 Room 306		0940		lead						
		706 Room 224		0955		lead						
		707 Room 205		1000		lead						
		708 Room 206		1005		lead						

Relinquished By: <u>Hyco ZA</u>		Date: <u>6/9/20</u>	Temp °C: <u>39</u> Acceptable: <u>(Y) N</u>	Submitted with COC? <u>(Y) N</u>	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Received By: <u>JR</u> (8)		Date: <u>6-10-20</u>					
Relinquished By: <u>YL</u>		Date: <u>6-10-20</u>	Temp °C: <u>43</u> Acceptable: <u>(Y) N</u>	All containers in tact? <u>(Y) N</u>	SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence		
Received in Lab By: <u>TUB</u> (8)		Date: <u>6/10/20</u>	Temp °C: <u>44.1</u> Acceptable: <u>(Y) N</u>			Tests within holding times <u>(Y) N</u>	
		Time: <u>11:50</u>	Acceptable: <u>(Y) N</u>	40 mL VOA vials free of headspace? <u>Y / N</u>			
		Time: <u>11:50</u>	Acceptable: <u>(Y) N</u>				

Page 4 of 5



SUBURBAN TESTING LABS



0063028
Kelly Mays

TAT (Circle One): Standard 24hr / 48hr / 72hr / Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Miller & Sons, Inc.

Address: _____

Phone: _____

Fax: _____

Contact Name: Brandy Zaia

Email: _____

Company Name: Brownstown CTC Campus
Address: 231 Snyder Road
Ephrata, PA 17522

Payment / P.O. Info: _____

Comments:

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
					<i>preserved w/ 20 drops HNO₃ pH < 2</i>						
	709 Room 124	6/9/20	1015	VF	lead TCB	1	PW	G	P		
	710 Room 117	6/9/20	1025	VF	lead 6/10/20 MISO	1	PW	G	P		
					(2) 250 mL P						

Relinquished By: <u>Kyle ZA</u>	Date: <u>6/9/20</u>	Temp °C: <u>3.2°</u> Acceptable: <u>Y</u> / N	Submitted with COC? <u>Y</u> / N	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Matrix Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options [] SDWA Reporting PWSID: _____ [] Fax [] Email [] Other [] Return a copy of this form with Report
Received By: <u>JM</u> (2)	Date: <u>6-10-20</u>		Number of containers match number on COC? <u>Y</u> / N				
Relinquished By: <u>KL</u>	Date: <u>6-10-20</u>	Temp °C: <u>4.1°</u> Acceptable: <u>Y</u> / N	All containers in tact? <u>Y</u> / N	Sample Type Key D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	SDWA Sample Types N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required		
Received in Lab By: <u>TLB</u> (2)	Date: <u>6/10/20</u>	Temp °C: <u>4.1°</u> Acceptable: <u>Y</u> / N	Tests within holding times <u>Y</u> / N				
	Date: <u>6/10/20</u>	Temp °C: <u>4.1°</u> Acceptable: <u>Y</u> / N	40 mL VOA vials free of headspace? <u>Y</u> / N				



Results Report

Order ID: 0062807

Miller & Sons Water Conditioning
2021 Horseshoe Road
Lancaster, PA 17602

Project: Health Science Campus
422 Beaver Valley Pike
Willow Street, PA 17584

Attn: Brandy Zaia

Regulatory ID:

Sample Number: 0062807-01

Site: 701- Simulation Office

Sample ID:

Collector: KF

Collect Date: 06/08/2020 12:45 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 0.003 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 21:39 RPV

Sample Number: 0062807-02

Site: 702- Kitchen Sink

Sample ID:

Collector: KF

Collect Date: 06/08/2020 12:25 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 0.021 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 21:41 RPV

Sample Number: 0062807-03

Site: 703- Faculty Lounge Restroom

Sample ID:

Collector: KF

Collect Date: 06/08/2020 12:30 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 21:47 RPV

Sample Number: 0062807-04

Site: 704- Faculty Office #2

Sample ID:

Collector: KF

Collect Date: 06/08/2020 12:35 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 21:49 RPV

Sample Number: 0062807-05

Site: 705- Faculty Office #3

Sample ID:

Collector: KF

Collect Date: 06/08/2020 12:40 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 21:51 RPV

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 06/19/2020 4:09 pm

0062807

STL_Results Revision #1.9

Effective: 04/16/2020





SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:


Kelly Mays
Client Services Supervisor

Report Generated On: 06/19/2020 4:09 pm 0062807
STL_Results Revision #1.9 Effective: 04/16/2020





6

0062807
Kelly MaysTAT (Circle One): Standard 24hr / 48hr / 72hr / Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Miller & Sons, Inc.

Address: _____ Phone: _____

Fax: _____

Contact Name: Brandy Zaia

Email: _____

ne: Health Science Campus
422 Beaver Valley Pike
Willow Street, PA 17584

Payment / P.O. Info: _____

Comments:

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	701 SIMULATION OFFICE	6/8/20	1245	KF	lead	1	PW	G	P		
	702 KITCHEN SINK		1225		lead	1	PW	G	P		
	703 FACULTY LOUNGE RESTROOM		1230		lead	1	PW	G	P		
	704 FACULTY OFFICE 42		1235		lead	1	PW	G	P		
	705 FACULTY OFFICE 43		1240		lead	1	PW	G	P		
	(5) 250mlp										
	↳ preserved w/ 15 drops										
	of HNO ₃ LMA 6/9/20										

Relinquished By: <u>[Signature]</u>	Date: <u>6/8/20</u>	Time: <u>1700</u>	Temp °C: <u>3.8</u>	Acceptable: <u>Y/N</u>	Sample Conditions	Submitted with COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Number of containers match number on COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	All containers in tact? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Tests within holding times <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Matrix Key	PW = Potable Water (not for SDWA compliance)	SDWA = Safe Drinking Water Act Potable Sample	Sample Type Key	SDWA Sample Types	Bottle Type Key	Preservative Key	Reporting Options	
Received By: <u>[Signature]</u>	Date: <u>6-9-20</u>	Time: <u>0830</u>	Temp °C: <u>3.6</u>	Acceptable: <u>Y/N</u>															
Relinquished By: <u>[Signature]</u>	Date: <u>6-9-20</u>	Time: <u>1140</u>	Temp °C: <u>3.6</u>	Acceptable: <u>Y/N</u>															
Received in Lab By: <u>[Signature]</u>	Date: <u>6/9/20</u>	Time: <u>1140</u>	Temp °C: <u>3.6</u>	Acceptable: <u>Y/N</u>															



Results Report

Order ID: 0063254

Miller & Sons Water Conditioning
2021 Horseshoe Road
Lancaster, PA 17602

Project: Lancaster Co. CTC Mount Joy
432 Old Market Street
Mount Joy, PA, 17552

Attn: Brandy Zaia

Regulatory ID:

Sample Number: 0063254-01

Site: 701 Room 118 Restroom

Sample ID:

Collector: KF

Collect Date: 06/11/2020 9:10 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/19/20 RPV 06/19/20 22:07 RPV

Sample Number: 0063254-02

Site: 702 Mens Restroom By 124

Sample ID:

Collector: KF

Collect Date: 06/11/2020 9:15 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 0.007 mg/L EPA 200.8 0.001 1 06/19/20 RPV 06/19/20 22:09 RPV

Sample Number: 0063254-03

Site: 703 Room 408 2 Bay Sink

Sample ID:

Collector: KF

Collect Date: 06/11/2020 9:20 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/19/20 RPV 06/19/20 21:45 RPV

Sample Number: 0063254-04

Site: 704 Room 414 2 Bay

Sample ID:

Collector: KF

Collect Date: 06/11/2020 9:25 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/19/20 RPV 06/19/20 22:11 RPV

Sample Number: 0063254-05

Site: 705 Cafeteria Handwash

Sample ID:

Collector: KF

Collect Date: 06/11/2020 9:30 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/19/20 RPV 06/19/20 22:13 RPV

Report Generated On: 06/25/2020 4:11 pm

0063254

STL_Results Revision #1.9

Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 0063254-06	Site: 706 Room 317 Restroom	Sample ID:
Collector: KF	Collect Date: 06/11/2020 9:35 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Metals									
Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/24/20	RPV	06/24/20 14:14	RPV

Sample Number: 0063254-07	Site: 707 Room 326 Welding	Sample ID:
Collector: KF	Collect Date: 06/11/2020 9:40 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Metals									
Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/24/20	RPV	06/24/20 14:16	RPV

Sample Number: 0063254-08	Site: 708 Room 339	Sample ID:
Collector: KF	Collect Date: 06/11/2020 9:45 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Metals									
Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/24/20	RPV	06/24/20 14:18	RPV

Sample Number: 0063254-09	Site: 709 Room 229 First Aid	Sample ID:
Collector: KF	Collect Date: 06/11/2020 9:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Metals									
Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/24/20	RPV	06/24/20 14:04	RPV

Sample Number: 0063254-10	Site: 710 Room 307 Restroom	Sample ID:
Collector: KF	Collect Date: 06/11/2020 9:55 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Metals									
Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/24/20	RPV	06/24/20 14:24	RPV

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 06/25/2020 4:11 pm 0063254
STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Kelly Mays
Client Services Supervisor

Report Generated On: 06/25/2020 4:11 pm 0063254
STL_Results Revision #1.9 Effective: 04/16/2020





0063254
Kelly Mays

TAT (Circle One): Standard 24hr / 48hr / 72hr / Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Miller & Sons, Inc.

Address: _____

Phone: _____

Fax: _____

Contact Name: Brandy Zaid

Email: _____

Comments:

Project Name: Lancaster Co. CTC Mount Joy

Address: 432 Old Market Street
Mount Joy, PA 17552

Payment / P.O. Info: _____

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
(10) 250mLP					Preserved 20 drops HNO ₃ pH<2 TUB						
701 Room 118 Restroom		6/11/20	0910	ICF	lead	1	PW	G	P		
702 Mens Restroom By 124			0915		lead						
703 Room 408 2 Bay Sink			0920		lead						
704 Room 414 2 Bay			0925		lead						
705 Cafeteria Handwash			0930		lead						
706 Room 317 Restroom			0935		lead						
707 Room 326 Workshop			0940		lead						
708 Room 339			0945		lead						


Relinquished By: <u>Kyle TA</u>	Date: <u>6/11/20</u>		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By: <u>Ally</u> 8	Time: <u>1700</u>		Submitted with COC? <input checked="" type="checkbox"/> Y / N	NPW = Non-Potable Water	P = Plastic	[] SDWA Reporting
Relinquished By: <u>Ally</u> 8	Date: <u>6/11/20</u>	Temp °C: <u>15.5</u>	Number of containers match number on COC? <input checked="" type="checkbox"/> Y / N	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	G = Glass	PWSID: _____
Received in Lab By: <u>CV</u> 8	Time: <u>1703</u>	Acceptable: <u>Y</u> / N	All containers in tact? <input checked="" type="checkbox"/> Y / N	PW = Potable Water (not for SDWA compliance)	O = Other	[] Fax
	Date: <u>6/11/20</u>	Temp °C: <u>1.2</u>	Tests within holding times <input checked="" type="checkbox"/> Y / N	SDWA = Safe Drinking Water Act Potable Sample	Preservative Key	[] Email
	Time: <u>1755</u>	Acceptable: <u>Y</u> / N	40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y / N	Sample Type Key	N = Sodium Thiosulfate	[] Other _____
	Date: <u>6-11-20</u>	Temp °C: <u>1.2</u>		SDWA Sample Types	A = Ascorbic Acid	[] Return a copy of this form with Report
	Time: <u>1755</u>	Acceptable: Y / N		G = Grab	H = HNO ₃	
				8HC = 8 Hr. Composite	C = HCl	
				24HC = 24 Hr. Composite	S = H ₂ SO ₄	
					OH = NaOH	
					O = Other	
					NA = None Required	

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SI F059 Rev 1.3 Effective May 16, 2013



SUBURBAN TESTING LABS

610-3

0063254
Kelly MaysTAT (Circle One): Standard 24hr / 48hr / 72hr / Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Miller & Sons, Inc.

Address: _____ Phone: _____

Contact Name: Brandy Zaid Fax: _____

Comments: _____

Project Name: Lancaster Co. CTC Mount JoyAddress: 432 Old Market Street
Mount Joy, PA 17552

Payment / P.O. Info: _____

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	709 Room 229 First Ave	6/11/20	0950	KF	lead	1	PW	G	P		
	710 Room 307 Restroom	6/11/20	0955	KF	lead	1	PW	G	P		

Relinquished By: <u>Lyle For</u>	Date: <u>6/11/20</u>		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By: <u>Allo 2</u>	Date: <u>6/11/2020</u>	Temp °C: <u>15.5</u>	Submitted with COC? <u>Y</u> / N	NPW = Non-Potable Water	P = Plastic	[] SDWA Reporting
	Time: <u>1703</u>	Acceptable: <u>Y</u> / N	Number of containers match number on COC? <u>0</u> / N	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	G = Glass	PWSID: _____
Relinquished By: <u>Allo 2</u>	Date: <u>6/11/2020</u>	Temp °C: <u>1.2</u>	All containers in tact? <u>Y</u> / N	PW = Potable Water (not for SDWA compliance)	O = Other	[] Fax
	Time: <u>1755</u>	Acceptable: <u>Y</u> / N	Tests within holding times? <u>Y</u> / N	SDWA = Safe Drinking Water Act Potable Sample		[] Email
Received in Lab By: <u>EW 2</u>	Date: <u>6-11-20</u>	Temp °C: <u>1.2</u>	40 mL VOA vials free of headspace? <u>Y</u> / N	Sample Type Key	Preservative Key	[] Other _____
	Time: <u>1755</u>	Acceptable: <u>Y</u> / N		D = Distribution	N = Sodium Thiosulfate	[] Return a copy of this form with Report
				E = Entry Point	A = Ascorbic Acid	
				R = Raw	H = HNO ₃	
				C = Check	C = HCl	
				S = Special	S = H ₂ SO ₄	
				M = Maximum Residence	OH = NaOH	
					O = Other	
					NA = None Required	



Results Report

Order ID: 0063255

Miller & Sons Water Conditioning
2021 Horseshoe Road
Lancaster, PA 17602

Project: Public Safety training Center CTC
101 Champ Boulevard
Manheim, PA, 17545

Attn: Brandy Zaia

Regulatory ID:

Sample Number: 0063255-01		Site: 701-Right Water Fountain		Sample ID: Office Area						
Collector: KF		Collect Date: 06/11/2020 11:10 am		Sample Type: Grab						
Department / Test / Parameter		Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/24/20 RPV 06/24/20 14:26 RPV

Sample Number: 0063255-02		Site: 702- Kitchen 2 Bay		Sample ID:					
Collector: KF		Collect Date: 06/11/2020 11:15 am		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/24/20 RPV 06/24/20 14:28 RPV

Sample Number: 0063255-03		Site: 703- Left Water Fountain		Sample ID: Main Entrance					
Collector: KF		Collect Date: 06/11/2020 11:20 am		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/24/20 RPV 06/24/20 14:30 RPV

Sample Number: 0063255-04		Site: 704- Janitors Closet		Sample ID:					
Collector: KF		Collect Date: 06/11/2020 11:25 am		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/24/20 RPV 06/24/20 14:32 RPV

Sample Number: 0063255-05		Site: 705- Tool Cage		Sample ID:					
Collector: KF		Collect Date: 06/11/2020 11:30 am		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/24/20 RPV 06/24/20 14:34 RPV

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 06/25/2020 4:10 pm
STL_Results Revision #1.9

0063255
Effective: 04/16/2020



SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:


Kelly Mays
Client Services Supervisor

Report Generated On: 06/25/2020 4:10 pm 0063255
STL_Results Revision #1.9 Effective: 04/16/2020





**SUBURBAN
TESTING LABS**



0063255
Kelly Mays

TAT (Circle One): Standard 24hr / 48hr / 72hr / Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Miller & Sons, Inc.

Address: _____ Phone: _____

_____ Fax: _____

Contact Name: Brandy Zaia Email: _____

Comments: _____

Name: Public Safety Training Center CTC
101 Champ Boulevard
Manheim, PA 17545

Payment / P.O. Info: _____

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
(5) 250mL					preserved 20 drops HNO ₃ pH < 2 TLB						
701	RIGHT WATER FOUNTAIN ^{office area}	6/11/20	1110	KCF	lead	1	PW	G	P		
702	KITCHEN 2 Bay		1115		lead	1	PW	G	P		
703	LEFT WATER FOUNTAIN - ENTRANCE ^{office}		1120		lead	1	PW	G	P		
704	JANITORS CLOSET		1125		lead	1	PW	G	P		
705	TOOL CAGE		1130		lead	1	PW	G	P		

Relinquished By: <u>[Signature]</u>	Date: <u>6/11/20</u>	Temp °C: <u>15.5</u> Acceptable: <u>Y</u> / N	Sample Conditions Submitted with COC? <u>Y</u> / N Number of containers match number on COC? <u>Y</u> / N All containers in tact? <u>Y</u> / N Tests within holding times? <u>Y</u> / N 40 mL VOA vials free of headspace? <u>Y</u> / N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Received By: <u>[Signature]</u> 5	Date: <u>6/11/2020</u> Time: <u>1703</u>					
Relinquished By: <u>[Signature]</u> 5	Date: <u>6/11/2020</u> Time: <u>1755</u>	Temp °C: <u>1.2</u> Acceptable: <u>Y</u> / N		Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence	Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required
Received in Lab By: <u>[Signature]</u> 5	Date: <u>6-11-20</u> Time: <u>1755</u>	Temp °C: <u>1.2</u> Acceptable: Y / N				



Results Report

Order ID: 0062811

Miller & Sons Water Conditioning
2021 Horseshoe Road
Lancaster, PA 17602

Project: Willow Street Campus
1730 Hans Herr Drive
Willow Street, PA 17584

Attn: Brandy Zaia

Regulatory ID:

Sample Number: 0062811-01		Site: 701- Front Office Restroom		Sample ID:						
Collector: KF		Collect Date: 06/08/2020 9:35 am		Sample Type: Grab						
Department / Test / Parameter		Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead 0.001 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 21:33 RPV

Sample Number: 0062811-02		Site: 702- Room 101 Culinary Cluster		Sample ID:						
Collector: KF		Collect Date: 06/08/2020 9:45 am		Sample Type: Grab						
Department / Test / Parameter		Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 21:59 RPV

Sample Number: 0062811-03		Site: 703- Faculty Restroom		Sample ID:					
Collector: KF		Collect Date: 06/08/2020 9:50 am		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 22:01 RPV

Sample Number: 0062811-04		Site: 704- Mens Restroom		Sample ID:					
Collector: KF		Collect Date: 06/08/2020 9:55 am		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 22:03 RPV

Sample Number: 0062811-05		Site: 705- Nurse Office		Sample ID:					
Collector: KF		Collect Date: 06/08/2020 10:00 am		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 06/18/20 RPV 06/18/20 22:05 RPV

Report Generated On: 06/19/2020 4:08 pm 0062811
STL_Results Revision #1.9 Effective: 04/16/2020



SUBURBAN TESTING LABS

Sample Number: 0062811-06	Site: 706- Conference Lunch Room	Sample ID:
Collector: KF	Collect Date: 06/08/2020 10:05 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:11	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0062811-07	Site: 707- Room 302 Diesel Tech	Sample ID:
Collector: KF	Collect Date: 06/08/2020 10:15 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:13	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0062811-08	Site: 708- 305 Auto Tech	Sample ID:
Collector: KF	Collect Date: 06/08/2020 10:20 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:15	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0062811-09	Site: 709- Room 310 Transportation	Sample ID:
Collector: KF	Collect Date: 06/08/2020 11:00 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:17	RPV
------	-------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0062811-10	Site: 710- Room 500 Auto Mechanics	Sample ID:
Collector: KF	Collect Date: 06/08/2020 11:05 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:29	RPV
------	-------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0062811-11	Site: 711- Room 501/503 Collision	Sample ID:
Collector: KF	Collect Date: 06/08/2020 11:10 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:23	RPV
------	-------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0062811-12	Site: 712- Room 303 Adult Auto	Sample ID:
Collector: KF	Collect Date: 06/08/2020 11:30 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:35	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Report Generated On: 06/19/2020 4:08 pm 0062811
STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 0062811-13	Site: 713- Room 301 Construction	Sample ID:
Collector: KF	Collect Date: 06/08/2020 11:35 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:37	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0062811-14	Site: 714- Room 300 Sports Med	Sample ID:
Collector: KF	Collect Date: 06/08/2020 11:40 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:39	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0062811-15	Site: 715- Room 401 Visual Comm	Sample ID:
Collector: KF	Collect Date: 06/08/2020 11:45 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:41	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0062811-16	Site: 716- Room 407 Vet Tech	Sample ID:
Collector: KF	Collect Date: 06/08/2020 11:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:43	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0062811-17	Site: 717- Room 409 Vet Assist	Sample ID:
Collector: KF	Collect Date: 06/08/2020 11:55 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:45	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0062811-18	Site: 718- Room 411 Adult CNA	Sample ID:
Collector: KF	Collect Date: 06/08/2020 12:00 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:47	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 0062811-19	Site: 719- Room 408 Adult Tech	Sample ID:
Collector: KF	Collect Date: 06/08/2020 12:05 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:49	RPV
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Report Generated On: 06/19/2020 4:08 pm 0062811
STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 0062811-20	Site: 720- Room 406 Manufacturing	Sample ID:
Collector: KF	Collect Date: 06/08/2020 12:10 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Metals									
Lead	< 0.001	mg/L	EPA 200.8	0.001	1	06/18/20	RPV	06/18/20 22:51	RPV

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Kelly Mays
Client Services Supervisor


Report Generated On: 06/19/2020 4:08 pm 0062811
STL_Results Revision #1.9 Effective: 04/16/2020





**SUBURBAN
TESTING LABS**

610-



0062811
Kelly Mays

TAT (Circle One): Standard 24hr / 48hr / 72hr / Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Miller & Sons, Inc.

Address: _____ Phone: _____

Fax: _____

Contact Name: Brandy Zava

Email: _____

Address: Willow Street Campus
1730 Hans Herr Drive
Willow Street, PA 17584

Payment / P.O. Info: _____

Comments:

STL Sample Number	Sample Description / Site ID:	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
						Matrix	Sample Type	Bottle Type	Preservative	
	(8) 250ml p ↳ preserved w/ 15 drops of HNO ₃ GPH 6/9/20									
	701 front office Restroom	6/9/20 0935	KF	lead	1	PW	G	P		
	702 Room 101 Culinary Center	0945		lead	1					
	703 JANUARY Restroom	0950		lead	1					
	704 Mens Restroom	0955		lead	1					
	705 Nurse office	1000		lead	1					
	706 Conference Lunch Room	1005		lead	1					
	707 Room 302 Diesel Tech	1015		lead	1					
	708 Room 305 1015 to Center Auto Tech	1020		lead	1					

Relinquished By: <u>Kyle Za</u>	Date: <u>6/9/20</u> Time: <u>1700</u>	Temp °C: <u>3.80</u> Acceptable: <u>Y/N</u>	Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By: <u>[Signature]</u>	Date: <u>6-9-20</u> Time: <u>08-30</u>		Submitted with COC? <u>(Y/N)</u>	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	P = Plastic G = Glass O = Other	[] SDWA Reporting PWSID: _____
Relinquished By: <u>[Signature]</u>	Date: <u>6-9-20</u> Time: <u>11-10</u>	Temp °C: <u>3.60</u> Acceptable: <u>Y/N</u>	Number of containers match number on COC? <u>(Y/N)</u>	Sample Type Key	Preservative Key	[] Fax [] Email [] Other _____
Received in Lab By: <u>GPH</u>	Date: <u>6/9/20</u> Time: <u>1140</u>		All containers in tact? <u>(Y/N)</u>	D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	[] Return a copy of this form with Report
			Tests within holding times <u>(Y/N)</u>	SDWA Sample Types		
			40 mL VOA vials free of headspace? <u>(Y/N)</u>	G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite		



**SUBURBAN
TESTING LABS**

2 of 3

TAT (Circle One): Standard 24hr / 48hr / 72hr / Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____



0062811
Kelly Mays

Client Name: Miller & Sons, Inc.

Address: _____

Contact Name: Brandy Zaid

Comments:

Name: Willow Street Campers
Address: 1730 Hans Herr Drive
Willow Street, PA 17584

Payment / P.O. Info: _____

STL Sample Number	Sample Description / Site ID	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
						Matrix	Sample Type	Bottle Type	Preservative	
	(8) 250 ml p ↳ preserved w/ 15 drops of HNO ₃ LTH 6/9/20									
	T09 Room 310 TRANSPORTATION	6/8/20 1100	KF	lead	1	PW	G	P		
	T10 Room 300 AUTO MECHANICS	1105		lead						
	T11 Room 501/503 COLLISION	1110		lead						
	T12 Room 303 ADULT AUTO	1130		lead						
	T13 Room 301 CONSTRUCTION	1135		lead						
	T14 Room 300 SPORTS MEN	1140		lead						
	T15 Room 401 VISUAL COMM	1145		lead						
	T16 Room 407 VLS TECH	1150		lead						

Relinquished By: <u>LTH</u>	Date: <u>6/8/20</u> Time: <u>1700</u>	Temp °C: <u>3.9</u> Acceptable: <u>Y/N</u>	Sample Conditions Submitted with COC? <u>Y/N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____
Received By: <u>Whe</u>	Date: <u>6-9-20</u> Time: <u>0830</u>		Number of containers match number on COC? <u>Y/N</u>	SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence	Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	<input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Return a copy of this form with Report
Relinquished By: <u>Whe</u>	Date: <u>6-9-20</u> Time: <u>1440</u>	All containers in tact? <u>Y/N</u>	Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite			
Received in Lab By: <u>LTH</u>	Date: <u>6/9/20</u> Time: <u>1140</u>	Temp °C: <u>3.6</u> Acceptable: <u>Y/N</u>	Tests within holding times? <u>Y/N</u>			
			40 mL VOA vials free of headspace? <u>Y/N</u>			

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.3 Effective May 16, 2013.



3043

TAT (Circle One): Standard 24hr / 48hr / 72hr / Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)


Order ID: _____

Client Name: Miller & Sons, Inc.

Address: _____

Contact Name: Brandy Zia

Comments: _____

0062811
Kelly Mays

Fax: _____

Email: _____

Payment / P.O. Info: _____

a: Willow Street Campus
1730 Hans Herr Drive
Willow Street, PA 17584

STL Sample Number	Sample Description / Site ID	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	(4) 250 mlp preserved w/ 15 drops of HNO ₃ LTH 6/9/20										
	717 Room 409 Vet Assist	6/8/20	1155	KF	lead	1	PW	G	P		
	718 Room 411 Adult CNA		1200		lead	1	PW	G	P		
	719 Room 408 Adult Tech		1205		lead	1	PW	G	P		
	720 Room 406 Manufacturing		1210		lead	1	PW	G	P		

Relinquished By: <u>KYC ZA</u>	Date: <u>6/8/20</u> Time: <u>1700</u>	Temp °C: <u>39.0</u> Acceptable: <u>Y/N</u>	Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By: <u>[Signature]</u>	Date: <u>6-9-20</u> Time: <u>08-30</u>		Submitted with COC? <u>(Y) N</u>	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	P = Plastic G = Glass O = Other	[] SDWA Reporting PWSID: _____
Relinquished By: <u>[Signature]</u>	Date: <u>6-9-20</u> Time: <u>11-49</u>	Temp °C: <u>3.6</u> Acceptable: <u>Y/N</u>	Number of containers match number on COC? <u>(Y) N</u>	Sample Type Key	Preservative Key	[] Fax [] Email [] Return a copy of this form with Report
Received in Lab By: <u>LTH (4)</u>	Date: <u>6/9/20</u> Time: <u>1140</u>	Temp °C: <u>3.6</u> Acceptable: <u>Y/N</u>	All containers in tact? <u>(Y) N</u>	SDWA Sample Types	N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	
			Tests within holding times <u>(Y) N</u>	G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	
			40 mL VOA vials free of headspace? <u>Y / N</u>			

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.3 Effective May 16, 2013.