



# SUBURBAN TESTING LABS

## Results Report

Order ID: 1C05049

Miller & Sons Water Conditioning  
2021 Horseshoe Road  
Lancaster, PA 17602

Project: Brownstown CTC Campus  
231 Snyder Road  
Ephrata, PA 17522

Attn: Brandy Zaia

Regulatory ID: 7361063

Sample Number: 1C05049-01

Site: 401

Sample ID: RM 340 - Restroom

Collector: KF

Collect Date: 03/29/2021 10:35 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead 0.005 mg/L EPA 200.8 0.001 1 04/05/21 MKR 04/06/21 12:20 MKR

Sample Number: 1C05049-02

Site: 402

Sample ID: RM 328 - Restroom

Collector: KF

Collect Date: 03/29/2021 10:40 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 04/05/21 MKR 04/06/21 12:22 MKR

Sample Number: 1C05049-03

Site: 403

Sample ID: RM 317 - 3 Bay right inside door

Collector: KF

Collect Date: 03/29/2021 10:45 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 04/05/21 MKR 04/06/21 12:24 MKR

Sample Number: 1C05049-04

Site: 404

Sample ID: RM 307 - Woodshop Restroom

Collector: KF

Collect Date: 03/29/2021 10:55 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 04/05/21 MKR 04/06/21 12:26 MKR

Sample Number: 1C05049-05

Site: 405

Sample ID: RM 306 - Green Room Restroom

Collector: KF

Collect Date: 03/29/2021 10:50 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 04/05/21 MKR 04/06/21 12:28 MKR

Report Generated On: 04/06/2021 4:19 pm

1C05049

STL\_Results Revision #1.9

Effective: 04/16/2020

1037F MacArthur Road, Reading, PA 19605

Phone: 610-375-TEST

Fax: 610-375-4090

suburbantestinglabs.com

**SUBURBAN TESTING LABS**



PA DEP # 06-00208

NJDEP# PA081

Page 1 of 5



# SUBURBAN TESTING LABS

Sample Number: 1C05049-06 Site: 406 Sample ID: RM 224 - Digital Design Printshop Slc  
Collector: KF Collect Date: 03/29/2021 11:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

## Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 04/05/21 MKR 04/06/21 12:31 MKR

Sample Number: 1C05049-07 Site: 407 Sample ID: RM 205 - Culinary Cluster 2 Bay Sink  
Collector: KF Collect Date: 03/29/2021 11:05 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

## Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 04/05/21 MKR 04/06/21 12:37 MKR

Sample Number: 1C05049-08 Site: 408 Sample ID: RM 206 - Comm Art Stop Sink  
Collector: KF Collect Date: 03/29/2021 11:10 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

## Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 04/05/21 MKR 04/06/21 12:39 MKR

Sample Number: 1C05049-09 Site: 409 Sample ID: RM 124 - IV Facilitator Handwash Sin  
Collector: KF Collect Date: 03/29/2021 11:15 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

## Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 04/05/21 MKR 04/06/21 11:18 MKR

Sample Number: 1C05049-10 Site: 410 Sample ID: RM 117 - MFG Cluster Slop Sink  
Collector: KF Collect Date: 03/29/2021 11:20 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

## Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 04/05/21 MKR 04/06/21 12:41 MKR

## Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 04/06/2021 4:19 pm 1C05049  
STL\_Results Revision #1.9 Effective: 04/16/2020

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com

**SUBURBAN TESTING LABS**



PA DEP # 06-00208  
NJDEP# PA081





# SUBURBAN TESTING LABS

## Drinking Water Results Report

Order ID: 1C05092

Miller & Sons Water Conditioning  
2021 Horseshoe Road  
Lancaster, PA 17602

Project: Health Science Campus  
422 Beaver Valley Pike  
Willow Street, PA 17584

Attn: Brandy Zaia

PWSID:

Sample Number: 1C05092-01

Site: 701 - Simulation Office

Sample ID:

Collector: KF

Collect Date: 03/30/2021 9:40 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	04/07/21	MKR	04/07/21 20:01	MKR
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 1C05092-02

Site: 702 - Kitchen

Sample ID:

Collector: KF

Collect Date: 03/30/2021 9:30 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	04/07/21	MKR	04/07/21 20:03	MKR
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 1C05092-03

Site: 703 - Faculty Office 1

Sample ID:

Collector: KF

Collect Date: 03/30/2021 10:05 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	04/07/21	MKR	04/07/21 18:43	MKR
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 1C05092-04

Site: 704 - Faculty Office 2

Sample ID:

Collector: KF

Collect Date: 03/30/2021 9:55 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	04/07/21	MKR	04/07/21 18:45	MKR
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 1C05092-05

Site: 705 - Faculty Office 3

Sample ID:

Collector: KF

Collect Date: 03/30/2021 9:50 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	04/07/21	MKR	04/07/21 18:47	MKR
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Report Generated On: 04/08/2021 12:51 pm  
STL\_DW\_Results Revision #1.7

1C05092  
Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605

Phone: 800-433-6595

Fax: 610-375-4090

suburbantestinglabs.com

**SUBURBAN TESTING LABS**



PADEP 06-00208



# SUBURBAN TESTING LABS

**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

MCL: Maximum Contaminant Level based on 40CFR part 141 and 143. MCL and Pass/Fail are provided for reference only.

RL: Reporting Limit. The lowest concentration reported for this sample. Results below the RL are considered Non-Detected.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Lisa F. Care  
Project Manager II

Report Generated On: 04/08/2021 12:51 pm 1C05092  
STL\_DW\_Results Revision #1.7 Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595 Fax: 610-375-4090 [suburbantestinglabs.com](http://suburbantestinglabs.com)

**SUBURBAN TESTING LABS**

PADEP 06-00208





# SUBURBAN TESTING LABS

## Drinking Water Results Report

Order ID: 1D01806

Miller & Sons Water Conditioning  
2021 Horseshoe Road  
Lancaster, PA 17602

Project: Lancaster Co. CTC Mount Joy  
432 Old Market Street  
Mount Joy, PA 17552

Attn: Brandy Zaia

PWSID:

Sample Number: 1D01806-01

Site: 707 - Room 118 Restroom

Sample ID:

Collector: EG

Collect Date: 04/01/2021 10:50 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 04/08/21 MKR 04/09/21 11:43 MKR

Sample Number: 1D01806-02

Site: 702 - Mens Restroom

Sample ID:

Collector: EG

Collect Date: 04/01/2021 11:05 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead 0.003 mg/L EPA 200.8 0.015 Pass 0.001 04/07/21 MKR 04/09/21 10:07 MKR

Sample Number: 1D01806-03

Site: 703 - Room 408 - Handwash

Sample ID:

Collector: EG

Collect Date: 04/01/2021 11:10 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 04/07/21 MKR 04/09/21 10:11 MKR

Sample Number: 1D01806-04

Site: 704 - Room 414 -Handwash

Sample ID:

Collector: EG

Collect Date: 04/01/2021 11:15 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 04/07/21 MKR 04/09/21 10:15 MKR

Sample Number: 1D01806-05

Site: 705 - Cafeteria Kitchen

Sample ID:

Collector: EG

Collect Date: 04/01/2021 11:20 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 04/07/21 MKR 04/09/21 10:20 MKR

Report Generated On: 04/12/2021 1:01 pm  
STL\_DW\_Results Revision #1.7

1D01806  
Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605

Phone: 800-433-6595

Fax: 610-375-4090

suburbantestinglabs.com

**SUBURBAN TESTING LABS**



PADEP 06-00208



# SUBURBAN TESTING LABS

Sample Number: 1D01806-06	Site: 706 - Room 317 Restroom	Sample ID:
Collector: EG	Collect Date: 04/01/2021 11:25 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 04/07/21 MKR 04/09/21 10:24 MKR

Sample Number: 1D01806-07	Site: 707 - Room 326 Restroom	Sample ID:
Collector: EG	Collect Date: 04/01/2021 11:40 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 04/07/21 MKR 04/09/21 10:41 MKR

Sample Number: 1D01806-08	Site: 708 - Room 339 Handwash	Sample ID:
Collector: EG	Collect Date: 04/01/2021 11:55 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead 0.001 mg/L EPA 200.8 0.015 Pass 0.001 04/07/21 MKR 04/09/21 10:46 MKR

Sample Number: 1D01806-09	Site: 709 - Room 229 Handwash	Sample ID:
Collector: EG	Collect Date: 04/01/2021 12:25 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 04/07/21 MKR 04/09/21 10:50 MKR

Sample Number: 1D01806-10	Site: 710 - Room 307 Restroom	Sample ID:
Collector: EG	Collect Date: 04/01/2021 12:10 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead 0.002 mg/L EPA 200.8 0.015 Pass 0.001 04/07/21 MKR 04/09/21 10:55 MKR

## Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 04/12/2021 1:01 pm 1D01806  
STL\_DW\_Results Revision #1.7 Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595 Fax: 610-375-4090 [suburbantestinglabs.com](http://suburbantestinglabs.com)

**SUBURBAN TESTING LABS**



PADEP 06-00208





# SUBURBAN TESTING LABS

## Drinking Water Results Report

Order ID: 1D01809

Miller & Sons Water Conditioning  
2021 Horseshoe Road  
Lancaster, PA 17602

Project: Public Safety Training Center  
101 Champ Boulevard  
Manheim, PA 17545

Attn: Brandy Zaia

PWSID:

Sample Number: 1D01809-01

Site: 701 - Burn Building - Janitors Closet

Sample ID:

Collector: KF

Collect Date: 03/31/2021 9:45 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 04/07/21 MKR 04/09/21 10:59 MKR

Sample Number: 1D01809-02

Site: 702 - Kitchen

Sample ID:

Collector: KF

Collect Date: 03/31/2021 10:20 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 04/07/21 MKR 04/08/21 20:06 MKR

Sample Number: 1D01809-03

Site: 703 - Burn Building Mens Restroom

Sample ID:

Collector: KF

Collect Date: 03/31/2021 9:50 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 04/07/21 MKR 04/08/21 21:31 MKR

Sample Number: 1D01809-04

Site: 704 - Janitors Closet

Sample ID:

Collector: KF

Collect Date: 03/31/2021 10:15 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 04/07/21 MKR 04/08/21 21:49 MKR

Sample Number: 1D01809-05

Site: 705 - Tool Cage

Sample ID:

Collector: KF

Collect Date: 03/31/2021 10:05 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead 0.007 mg/L EPA 200.8 0.015 Pass 0.001 04/07/21 MKR 04/08/21 21:53 MKR

Report Generated On: 04/12/2021 1:01 pm 1D01809

STL\_DW\_Results Revision #1.7 Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605

Phone: 800-433-6595

Fax: 610-375-4090

suburbantestinglabs.com

**SUBURBAN TESTING LABS**



PADEP 06-00208



# SUBURBAN TESTING LABS

**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

MCL: Maximum Contaminant Level based on 40CFR part 141 and 143. MCL and Pass/Fail are provided for reference only.

RL: Reporting Limit. The lowest concentration reported for this sample. Results below the RL are considered Non-Detected.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Lisa F. Care  
Project Manager II

Report Generated On: 04/12/2021 1:01 pm 1D01809  
STL\_DW\_Results Revision #1.7 Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595 Fax: 610-375-4090 [suburbantestinglabs.com](http://suburbantestinglabs.com)

**SUBURBAN TESTING LABS**

PADEP 06-00208